

Hi all,

Steve, here are the results from the recent acoustical testing we had completed with our 2, 5, and 10mm thicknesses of QT. Formal reports should be coming in a couple of weeks. Please let me know if you have any questions about these tests.

Assemblies tested:

Prime Waterproof flooring

2mm, 5mm and 10mm

6" slab

No Ceiling

2mm = STC 50 / IIC 50

5mm = STC 50 / IIC 53

10 mm = STC 52 / IIC 53

**SHARON PALEY**

Acoustic Engineer, INCE

**ecore**